

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3774-1725:0105

Page 1 of 1

CATEGORY: Electric Locks

LISTEE: STANLEY SECURITY SOLUTIONS, 6161 E. 75th Street, Indianapolis, IN, 46250
Contact: Robert Strong (317) 806-3288 Fax (317) 806-3337
Email: bstrong@stanleyworks.com

DESIGN: Models 30HEL and 30HEU with 3/4" latch bolt mortise type rated 24 VDC; Models 34HV and 35HV with 3/4" latch throw mortise type battery operated. For use in doors not to exceed 4 ft. in width and 10 ft. in height rated up to and including 3 hours. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed electrically controlled single point locks or latches for fire rated doors. Authority having jurisdiction shall be consulted prior to installation. Refer to Manufacturer's Installation Instruction Manual for details.

NOTE: Formerly 3774-1175:109

4-2-10 MA



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **April 02, 2010**

Listing Expires **June 30, 2010**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division